Electric Outages Lewes BPW

Month	Date	Circuit	Customers Interrupted	Duration	Cause	Percent System Reliability
January 2017	1/23/17	3	5	25	Wind	99.99956%
	2/18/17	3	4	120	Equipment damage	99.99969%
February 2017	2/20/17	3	5	60	Electrical failure	
	3/10/17	1	3	30	Squirrel	99.99881%
March 2017	3/11/17	1	2	60	Squirrel	
	3/17/17	3	1	120	Equipment damage	
	4/14/17	1	3	60	Squirrel	99.96995%
April 2017	4/20/17	1	3	50	Equipment worn out	
_	4/27/17	3	3	120	Equipment Damage	
	4/30/17	3	2	60	Equipment Damage	
May 2017	5/2/17	2	5	30	Equipment Damage	
-	5/17/17	2	1	45	Equipment Damage	



